




## SAFETY ALERT BULLETIN



**On December 5, 2005, at about 3:05 p.m., a contractor employee working on top of a shop building was seriously injured when he slid off the roof and fell 16 feet to the ground. The victim broke his left forearm and left leg, just above the ankle in the fall.**

**The side of the shop roof where the sun was shining was dry, but when the employee stepped on the opposite side, which was wet, he slid down and off the roof.**

### **RECOMMENDATIONS:**

**Employees should wait until work areas are examined and made safe by their supervisors or the person in charge before attempting any work.**

**ACCIDENT REDUCTION PROGRAM**